



CITY OF SANTA FE SPRINGS FIRE DEPARTMENT

Fire Protection Division • Environmental Protection Division

11300 Greenstone Avenue • Santa Fe Springs, CA 90670-4619 • (562) 944-9713 • FAX (562) 941-1817 • fire@santafesprings.org

NOTICE OF VIOLATION & ORDER TO COMPLY

Business Name: Associated Plating Contact: Cindy Wilson
Site Address: 9636 Ann St. Unit # _____ Telephone: 946-5525
Business Owner: _____ Inspected by: Kallman/Hall

☒ FIRST NOTICE 3-10-00
DATE☐ SECOND NOTICE _____
DATE☐ THIRD NOTICE _____
DATECompliance Due Date 4-10-00

Compliance Due Date _____

Compliance Due Date _____

1st Notice NO CHARGE
2nd Notice \$500 Fine
3rd Notice \$100 Fine
Office Meeting \$500 Fine

CORRECT THE BELOW STATED VIOLATIONS, SIGN AND RETURN FORM TO AVOID LATE FINES

☐ ← INT.

ITEM	DESCRIPTION OF VIOLATIONS:
	<u>SENT VIA MAIL</u>
1.	<u>Remove material released to secondary containment from primary vessel failure on plating line (UFC 800.1.5.2)</u>
2.	<u>Ensure waste containers are closed except when adding or removing materials (22CCR66265.173(b))</u>
3.	<u>Provide implementation schedule to provide proper separation of incompatible cyanide destruct and acids. (UFC 800.11.8).</u>
4.	<u>Keep an inspection log of wastes and treatment areas (22CCR66265.15(d)) (22CCR66265.174).</u>
5.	<u>Do not discharge storm water run off to the sewer without obtaining sanitation district approval (City Ord. Ch. 97)</u>
6.	<u>Ensure containment trenches are free of hazardous materials (UFC 800.1.5.2).</u>

The above conditions or practices represent a violation of the referenced code for which there are civil and or criminal penalties. Failure to correct the above violations by the specified due date may result in legal action being taken against the above parties. The giving of this notice and recent inspection of your facility is not a representation by the City of Santa Fe Springs that no other violations exist on your premises. After you have corrected the violation, please sign and print your name along with the date and return this notice with any required documentation to the Santa Fe Springs Fire Department at the above address.

I HEREBY CERTIFY THAT THE ABOVE SPECIFIED VIOLATIONS HAVE BEEN CORRECTED.

Cindy Wilson
Signature of Responsible Party

Cindy Wilson
Name - Printed

4/10/00
Date

April 10, 2000

Implementation Schedule for Incompatible Chemical Segregation in Stripping Room

Re: Santa Fe Springs Fire Department Notice of Violation issued 3/10/00.
Associated Plating Acquisition Corp.
9636 Ann Street
Santa Fe Springs, CA 90670

A non-flammable separation (masonry) will be constructed in the stripping room to segregate the acids from cyanides. The new construction will begin from the back wall of the room to divide the room into two separate areas, the left side for cyanides, the right side for acids. The wall will extend at least 18" above the top of the tallest tank.

We are in the process of obtaining quotes by outside sources. All quotes to be submitted by 4/21/00.

Wall to be constructed and project completed by 5/19/00.

Electronic
Plating
Service, Inc.



A Connector Service Corporation Company

April 10, 2000

Mr. Tom Hall
Santa Fe Springs Fire Department
11300 Greenstone Avenue
Santa Fe Springs, CA 90670-4619

Mr. Hall,

Please find attached a copy of the Notice of Violation issued 3/10/00 to Associated Plating.

All items have been addressed and are complete. The plan for the construction of a wall to provide segregation of incompatible chemicals is included.

Hard copies of all will be mailed today. If there are any questions, please call.

Regards,

Cindy Wilson
Safety & Environmental Manager